



- NOTES
1. MANHOLE SECTIONS PER ASTM C-478
  2. O-RING JOINTS PER ASTM C-443
  3. PIPE GASKET SEALS PER ASTM C-923
  4. CONCRETE CLASS 'C' 5,000 PSI MIN AT 28 DAYS.

PLAN VIEW

Earnhart Hill Regional  
 Water and Sewer District  
 2030 Stoneridge Dr.  
 P.O. Box 151  
 Circleville, OH 43113

## SANITARY LIFT STATION - PLAN

Revised  
04-30-07

Scale  
None

Page 1 of 1

Drawing : C-2