



NOTES

1. COORDINATE WITH EHRWSD FOR SHUT DOWN OF WATER LINE.
2. PROVIDE CONCRETE THRUST BLOCKS AT ALL FITTINGS IN ACCORDANCE WITH EHRWSD STANDARDS.
3. NUMBER OF JOINTS TO BE RESTRAINED UP AND DOWN STREAM TO BE DETERMINED BY LINE SIZE, PRESSURE, AND SOIL TYPE. EHRWSD WILL MAKE FINAL DETERMINATION.

Earnhart Hill Regional
 Water and Sewer District
 2030 Stoneridge Dr.
 P.O Box 151
 Circleville, OH 43113

WATER LINE LOWERING

Revised
 06-24-08

Scale
 None

Page 1 of 1

Drawing : D-5