



INTERIOR PLAN  
NTS

NOTES:

1. PRESSURE REDUCING STATION SHALL BE MANUFACTURED BY ENGINEERED FLUID, INC. (E.F.I.), CENTRALIA, ILLINOIS.
2. PRESSURE REDUCING VALVES SHALL BE CLA-VAL MODEL 90G-01ABCS WITH STAINLESS STEEL TRIM, AND X-101 VALVE POSITION INDICATORS.
3. ALL PIPING SHALL BE SCHEDULE 40 STEEL PIPE WITH FUSION BONDED EPOXY ON INTERIOR.
4. ALL FITTINGS SHALL BE INTEGRAL TO THE STATION.
5. PROVIDE TWO COATS TENEMEC SERIES 66 HI-BUILD EPOXOLINE ON ALL STEEL SURFACES, MIN. 4 MILS DFT PER COAT.
6. PROVIDE EHRWSD WITH SHOP SUBMITALS FOR APPROVAL PRIOR TO FABRICATION.
7. HYDRAULIC CONDITIONS

INLET PRESSURE: \_\_\_\_\_

SMALL PRV SETTING: \_\_\_\_\_

LARGE PRV SETTING: \_\_\_\_\_