

and yoke assembly (O.S. & Y.)

Meter Setting	Α
2" - 10"	6'
12"	7'

Use of a Sump Pump in lieu of providing adequate drainage is not permitted. Where adequate drainage is not available or proves to be inadequate a Sump Pump will be required by EHRWSD.

The Vault Floor shall be a min. of 18" above the flow line of the Drainage Ditch or Storm Sewer.

Earnhart Hill Regional Water and Sewer District

2030 Stoneridge Dr. P.O Box 151 Circleville, OH 43113

2" - 12" METER SETTING - PROFILE

Revised Scale Page 1 of 1 Drawing: D-10B 05-07-07 None