

NOTE:

- -TRACER WIRE SHALL TERMINATE IN BOX WITHIN 12" OF LID.
- -TANDEM SETTER USED WHEN PRESSURES EXCEED 80PSI. CONTRACTOR RESPONSIBLE TO DETERMINE PRESSURE ON SITE PRIOR TO ORDERING.
- -TANDEM SETTER SHALL INCLUDE MATCHING S BAR, WILKINS #600XL PRESSURE REGULATOR WITH CHROME INTERNAL PARTS NO LEAD, AND THREAD ADAPTERS

Earnhart Hill Regional Water and Sewer District

2030 Stoneridge Dr. P.O Box 151 Circleville, OH 43113

3/4" METER BOX INSTALLATION

Revised O1-06-2023 Scale Page 1 of 1 Drawing: D-12A