

NOTE:

- -TRACER WIRE SHALL TERMINATE IN BOX WITHIN 12" OF LID.
- -TANDEM SETTER USED WHEN PRESSURES EXCEED 80PSI. CONTRACTOR RESPONSIBLE TO DETERMINE PRESSURE ON SITE PRIOR TO ORDERING.
- -TANDEM SETTER SHALL INCLUDE MATCHING S BAR, WILKINS #600XL PRESSURE REGULATOR WITH CHROME INTERNAL PARTS NO LEAD, AND THREAD ADAPTERS

Earnhart Hill Regional Water and Sewer District

2030 Stoneridge Dr. P.O Box 151 Circleville, OH 43113

1" METER BOX INSTALLATION

Revised Scale O1-06-2023 None Page 1 of 1 Drawing: D-12B