



| | | D.I. | PVC |
|-------------------|-------------------|-----------------------------|-----------------------------|
| UNDER PAVED AREAS | BEDDING | GRAVEL/SAND | GRAVEL/SAND |
| | INITIAL BACKFILL | GRAVEL/SAND | GRAVEL/SAND |
| | TRENCH BACKFILL** | COMPACTED GRANULAR MATERIAL | COMPACTED GRANULAR MATERIAL |
| UNDER GRASS AREAS | BEDDING | COMPACTED NATIVE MATERIAL | GRAVEL/SAND* |
| | INITIAL BACKFILL | COMPACTED NATIVE MATERIAL | GRAVEL/SAND* |
| | TRENCH BACKFILL | COMPACTED NATIVE MATERIAL | COMPACTED NATIVE MATERIAL |

NOTES

1. NATIVE MATERIAL SHALL BE FREE FROM TRASH, ROOTS, DEBRIS, EXCESSIVE MOISTURE, AND OBJECTS LARGER THAN 1".
2. GRANULAR MATERIAL SHALL BE ODOT ITEM #411.
3. SAND SHALL NOT CONTAIN OBJECTS LARGER THAN 1".
4. GRAVEL SHALL BE #8 OR #57 ROUNDS.
5. PROVIDE #8 OR #57 GRAVEL, OR SAND FOR BEDDING MATERIAL TO THE DEPTH REQUIRED BY EHRWSD WHEN UNSTABLE TRENCH BOTTOMS ARE ENCOUNTERED.
6. MANUALLY COMPACT EMBEDMENT MATERIAL FILLING ALL VOIDS AROUND PIPE.
7. TRENCH BACKFILL TYPE SHALL BE PER GENERAL NOTES AND SPECIFICATIONS.
8. SETTLEMENT OF TRENCH DUE TO FAILURE OF PROPER COMPACTION SHALL BE REPAIRED BY THE CONTRACTOR.

* Unless otherwise noted on the plans. ** Backfill under County Roads per Co Eng.