



- 72" tall RhinoDome utility marking post by Rhino Marking and Protection Services with EHRWSD name.
- Install directly over the waterline at road crossings, next to tracer wire access points (snake pits), and a minimum of 2 feet from valves and hydrants, and tracer wire access points as noted on the plans.

## MARKER POST DETAIL