

HYDRANTS SHALL BE SET IN 4 CUBIC FEET OF CRUSHED STONE TO ALLOW FOR PROPER DRAINAGE OF THE HYDRANT. RECOMMENDATIONS OF THE AWWA SHOULD BE FOLLOWED WHEN INSTALLING THE HYDRANTS.

POST HYDRANTS SHALL BE KUPFERLE ECLIPSE # 2 AND SHALL NOT BE USED ON MAINLINES LARGER THAN 4"

Earnhart Hill Regional Water and Sewer District

2030 Stoneridge Dr. P.O Box 151 Circleville, OH 43113

POST HYDRANT INSTALLATION

Revised Scale 05-01-18 None

Scale None

Page 1 of 1 Drawing: D-24