



PLACE WIRE MARKER POSTS AS REQUIRED PER PLANS.
 BORE PIT TO BE BACKFILLED AND COMPACTED IN 6" LIFTS WITH MATERIAL REMOVED.
 FLOW OF DITCH MUST BE MAINTAINED AT ALL TIMES.
 ANY EXISTING TILES DAMAGED SHALL BE REPLACED PER STANDARD DRAWING D-15.

Earnhart Hill Regional
 Water and Sewer District
 2030 Stoneridge Dr.
 P.O Box 151
 Circleville, OH 43113

DIRECTIONAL BORING - ROADWAY

Revised
 08-07-19

Scale
 None

Page 1 of 1

Drawing : D-27