



Notes:

1. Refer to attached set of installation rules Drawing D-29A which accompany this drawing.
2. A leak detector check assembly shall be required on backflow protection devices for fire systems 6" and larger.

For waterlines 2 1/2" to 10", a Zurn Model 375 reduced pressure principle assembly

Attached set of Installation Rules : Drawing D-29A Accompany this Drawing