



NOTES

1. COORDINATE WITH EHRWSD FOR SHUT DOWN OF WATER LINE.
2. PROVIDE MECHANICAL JOINT RESTRAINTS AT ALL FITTINGS IN ACCORDANCE WITH EHRWSD STANDARDS.
3. NUMBER OF JOINTS TO BE RESTRAINED UP AND DOWN STREAM TO BE DETERMINED BY LINE SIZE, PRESSURE, AND SOIL TYPE. EHRWSD WILL MAKE FINAL DETERMINATION.
4. THE RELOCATED LINES SHALL BE LAID TO THE NEW LINE AND GRADE, TESTED AND DISINFECTED PRIOR TO SHUT DOWN OF EXISTING WATER MAIN AND CONNECTION OF THE RELOCATED LINES TO THE EXISTING MAIN.
5. ALL WATER LINES SHALL BE DISINFECTED BY SWABBING WITH A 5 PERCENT HYPOCHLORITE SOLUTION IN ACCORDANCE WITH THE APPLICABLE SECTIONS OF A.W.W.A. C-601.