



NOTES:

1. ALL CONNECTIONS SHALL USE MJ FITTINGS RESTRAINED TO PIPE.
2. ANCHORING RINGS SHALL BE PROVIDED AT ALL LOCATIONS WHERE FUSIBLE PIPE IS CONNECTED TO UNRESTRAINED PUSH ON JOINT TYPE PIPE.

END CONNECTION WITH ANCHORING RING

